

	Minimum	Ideal	Maximum
Copper Ions	0	0.1 - 0.2 ppm	0.2 ppm
Free Chlorine	0	0.4 - 1.5 ppm	3.0 ppm
Combined Chlorine	0	0 ppm	0.2 ppm
Ph	7.2	7.4 - 7.6	7.8
Total Alkalinity	100ppm	100 - 140 ppm	140 ppm
Calcium Hardness	150ppm	200 - 400 ppm	500 - 1000 ppm
Stabilizer (Cyanuric Acid)	10ppm	10 - 20 ppm	50 ppm